

<b>AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT</b>		1. CONTRACT ID CODE		PAGE OF PAGES	
2. AMENDMENT/MODIFICATION NO <b>0003</b>		3. EFFECTIVE DATE <b>6/16/00</b>		4. REQUISITION/PURCHASE REQ #	
6. ISSUED BY Department of the Treasury Federal Law Enforcement Training Center Procurement Division, Building 28 Glynco, Georgia 31524		7. ADMINISTERED BY (if other than Item 6) Gail P. Ashurst Construction Contracts Branch  See Block 6 for address		5. PROJECT NO. (If Applicable)	
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)		(x)		9A. Amendment of Solicitation No <b>FTC 00-03</b>	
		<b>XX</b>		9B. Dated (See Item 11) <b>5/11/00</b>	
				10A. Modification of Contract/Order No	
				10B. Dated (See Item 13)	
CODE		FACILITY CODE			

**11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS**

☒ The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer: ☒ is extended, ☐ is not extended.

Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods

(a) By completing Items 8 and 15, and returning one copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGEMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified

**12. ACCOUNTING AND APPROPRIATION DATA (If required)****N/A****13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14**

(x)	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (specific authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. ITEM IN 10A.
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b)
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
	D. OTHER (Specify type of modification and authority)

**E. IMPORTANT:** Contractor ☐ is not, ☒ is required to sign this document and return one copies to the issuing office.

**14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible)****The Purpose of this Amendment is to:**

A. Technical Proposals are due at the FLETC, Procurement Office, Bldg. 93 on or before June 27, 2000 by 2:00 PM.

B. Questions submitted by Prospective Offerors. **SEE ATTACHED**

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print) <b>Gail P. Ashurst</b> <b>Contracting Officer</b>	
15B. CONTRACTOR/OFFEROR  (Signature of person authorized to sign)	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA BY _____ (Signature of Contracting Officer)	16C. Date Signed

A. Receipt of Technical Proposals, Step One, is changed from June 20, 2000, to June 27, 2000, at 2:00 p.m.

B. The following questions and answers are provided:

1.

QUESTION: Room safes require floor stands approximately 19 inches high. Is the stand to be metal or wood? Should it be a standard 2-drawer file cabinet which measures approximately 26 inches high X 14 inches wide X 22 inches deep? Width and depth required? Is this a guest room with bed which may require a wood nightstand/ mounted to floor - Wood floor or concrete?

ANSWER: The stand is to be constructed of metal, stand approximately 19 inches high, and mounted to a concrete floor. The stand shall fully support the safe and be approximately the same width and depth measurement. The safe is to be securely mounted onto the floor stand. The Government may or may not utilize a separate nightstand.

2.

QUESTION: A pin number with a key override are required to operate the safes. The Mossberg Instant Access Safe was designed for the purpose of securing weapons for law enforcement officers both at home and away from the home. The safe was **designed to eliminate keys** which the law enforcement market required. In place of the keys, the following features were engineered into the system:

2 - 9 volt battery system	1 internally and 1 externally. Batteries are alarmed for low voltage. Approximately 3000 opening life cycle at room temperature.
Portable	The Mossberg Safe is portable. It can be removed from secured mounting steel plate. The plate release is inside the safe. Engineered to be pry proof.
Keypad Code	Key code combination can be from 0 to 8 digits. We recommend minimum of 4 digits, which has a probability of 10,000 combinations. Key code can be changed within 30 seconds. Mossberg maintains a 24 hour/7 days a week telephone/page number to access a Mossberg engineer to assist the opening of the safe by an authorized person only. This system will allow an authorized person to enter a backdoor code, if code had been forgotten and also allows a mechanical method if a failure should occur.
Alarmed	Each safe has an alarm installed. After 18 illegal individual key entries or less, an alarm will sound. This will last 30 seconds at each attempt. After this attempt, you will be able to detect that someone has attempted an illegal entry when you enter the correct code.

ANSWER: The minimum needs of the Government require access to the safe by PIN number with key override. Key code combination shall be a minimum of 4 digits and a maximum of 10 digits. The minimum internal and external dimensions were provided by amendment 0002. The safe is not required to be portable.

3.

QUESTION: Will not accept separate bids for safes and door locks. Mossberg entered this solicitation with the understanding that we could bid on the safes only. Not the door locks. Mossberg Safe Systems only manufactures safes. 2 types. The portable Instant Access Safe and the Hotel Floor Safe which is also a key pad entry, with a key and manual override. The Hotel Floor Safe is the approximate size of a 2-drawer file cabinet. Alarmed for unauthorized entry, motion and tilt. Can be hardwired to house alarm and electrical. This safe does not meet the dimensions of the tabletop spec requirements but the Mossberg Instant Access Safe does meet the spec dimensions.

ANSWER: Separate bids for the locks and safe will be acceptable. Addendum to FAR 52.212-1, paragraph 6 is changed as follows:

(h) Multiple awards. The Government intends to award one or more requirements - type contracts. Awarded items of a contract may include all items identified in the solicitation or individual items. Offerors determined to be acceptable under Step One are requested at Step Two to submit pricing information on each contract line item for which a contract is sought. The Government shall determine after receipt of Step Two submissions whether single or multiple awards are in the Government's best interest. **DO NOT SUBMIT PRICING INFORMATION DURING STEP ONE.**